


# Predicting Performance and Designing Systems

Small Wind Systems Tutorial Village Power Conference Workshop




## **Performance Specifications**

Based on averaged field test data






### **Modeling Wind Speed Distributions**



Frequency
Distribution
Defined by One
Number (average
wind speed)

# Based on Monthly or Annual Average Wind Speed

#### Rayleigh Wind Speed Distribution






### Weibull "K" Shape Factor

- Widens / NarrowsSpeed Distribution
- **❖** Inland: K = 1.5 2.5
- **❖** Coastal: K = 2.5 3.5
- **❖** Trade Wind: K = 3 4
- Higher K = Less Energy
- K = 2 is a Rayleigh Distribution

Two Parameters (V and K) Define the Wind







### "Bins" Method

- Multiply the Turbine Power Curve by the Wind Speed Frequency Distribution Curve on a Bin by Bin Basis
- ❖ Sum the Results from 0
   ~20 m/s = Mean Power
  Output (MPO), in Watts
- Daily Energy Produced= MPO x 24 Hrs
- Annual Energy Output (AEO) = MPO x 8765Hrs


#### POWER CURVE



#### WIND SPEED FREQUENCY




#### ANNUAL ENERGY OUTPUT






### **Performance Prediction**

# Annual average taken from US-DOE Wind Atlas,



#### or New Generation Map ...





# and inputted into performance model

#### WindCad Turbine Performance Model

**BWC EXCEL-S, Grid - Intertie** 

Prepared For: SCE Customer
Site Location: Tehachapi, CA
Data Source: U.S. DOE Wind Atlas
Date: 11/12/00

Inputs:	
Ave. Wind (m/s) =	5.5
Weibull K =	2
Site Altitude (m) =	50
Wind Shear Exp. =	0.180
Anem. Height (m) =	10
Tower Height (m) =	30
Turbulence Factor =	10.0%

Results:	
Hub Average Wind Speed (m/s) =	6.70
Air Density Factor =	0%
Average Output Power (kW) =	2.07
Daily Energy Output (kWh) =	49.8
Annual Energy Output (kWh) =	18,166
Monthly Energy Output =	1,514
Percent Operating Time =	80.6%

Weibull Performance	Calculations		
Wind Speed Bin (m/s)	Power (kW)	Wind Probability (f)	Net kW @ V
1	0.00	3.46%	0.000
2	0.00	6.57%	0.000
3	0.00	9.03%	0.000
4	0.16	10.64%	0.017
5	0.45	11.35%	0.051
6	0.89	11.22%	0.099
7	1.52	10.40%	0.158
8	2.33	9.13%	0.213
9	3.23	7.61%	0.245
10	4.26	6.05%	0.257
11	5.35	4.59%	0.246
12	6.50	3.34%	0.217
13	7.78	2.33%	0.181
14	9.09	1.56%	0.142
15	10.26	1.00%	0.103
16	10.75	0.62%	0.066
17	10.66	0.37%	0.039
18	10.30	0.21%	0.022
19	9.85	0.12%	0.011
20	9.41	0.06%	0.006
1999, BWC	Totals:	99.65%	2.074

### WindCAD

- Spreadsheet Model for Wind Turbine Performance Prediction
- Created for BWC Turbines, but Easily Adapted to any Wind Turbine (modify power curve data)
- Simple Inputs
- Use with Monthly and Annual Wind Averages ... Not for Shorter Periods



**Instructions** 

#### WindCad Turbine Performance Model

#### **BWC XL.1 24VDC Battery Charging Version**

Prepared For: Site Location: Data Source:

Date: 11/29/00

1.1 kW

speeds. Use of daily or hourly

#### 

1.03

Turbulence Factor = 10.0% Perf. Safety Margin = 5.0%

Tower Height (m) = 24

Monthly Energy Output =	190
Percent Operating Time =	76.1%

Weibull Performance	Calculations			_
Wind Speed Bin (m/s)	Power (kW)	Wind Probability (f)	Net kW @ V	Weibull Calculations:
1	0.00	4.37%	0.00	Wind speed probability is
2	0.00	8.17%	0.00	calculated as a Weibull curve
3	0.02	10.96%	0.00	defined by the average wind
4	0.05	12.49%	0.01	speed and a shape factor, K. To
5	0.10	12.78%	0.01	facilitate piece-wise integration, the wind speed range is broken
6	0.17	11.99%	0.02	down into "bins" of 1 m/s in
7	0.28	10.47%	0.03	width (Column 1). For each wind
8	0.44	8.56%	0.04	speed bin, instantaneous wind
9	0.60	6.59%	0.04	turbine power (W, Column 2)) is multiplied by the Weibull wind
10	0.76	4.79%	0.04	speed probability (f, Column 3).
11	0.92	3.30%	0.03	This cross product (Net W,
12	1.10	2.15%	0.02	Column 4) is the contribution to
13	1.19	1.33%	0.02	average turbine power output contributed by wind speeds in
14	1.21	0.79%	0.01	that bin. The sum of these
15	1.20	0.44%	0.01	contributions is the average
16	1.17	0.24%	0.00	power output of the turbine on a
17	1.13	0.12%	0.00	continuous, 24 hour, basis. Best results are achieved using
18	1.09	0.06%	0.00	annual or monthly average wind

Instructions

2000. Bergey Windpower

Inputs: Use annual or monthly Average Wind speeds. If Weibull K is not known, use K = 2 for inland sites, use 3 for coastal sites, and use 4 for island sites and trade wind fegimes. Site Altitude is meters above sea level. Wind Shear Exponent is best assumed as "17" or 0.143. For rough terrainor high tributeneous every smooth terrain or open water use 0.110. Anemometer Height is for the data used for the Average Wind speed. If unknown, use 10 meters. Tower Height is the nominal height, eg.: 24 meters. Turbulence Factor is a derating for turbulence, product variability, and other performance influencing factors. Use 0.1 (10%) -0.15 (15%) is most\_esse. Performance Safety Margin is a derating that accounts for unuseable energy (eg.: batteries full) and adds a margin of safety in satisfying the load requirements. Use 0.05 (5%) for remote homes and village power sites with back-up power. Use 0.15 (15%) -0.25 (25%) for telecommunication applications with back-up power. Use 0.2 (20%) -0.4 (40%) for high-priority foads at sites without back-up power (should have solar component).

0.03%

99.62%

Limitations: This model uses a mathmatical idealization of the wind speed probability. The validity of this assumption is reduced as the time period under consideration (ie, the wind speed averaging period) is reduced. This model is best used with annual or monthly average wind speeds. Use of this model with daily or hourly average wind speed data is not recommended because the wind will not follow a Weibull distribution over short periods. Consult Bergey Windpower Co. for special needs. Actual Performance May Vary!

#### WindCAD

#### Inputs:

Ave. Wind (m/s) = 5.00

Weibull K = 2

Site Altitude (m) = 300

Wind Shear Exp. = 0.200

Anem. Height (m) = 10

Tower Height (m) = 24

Turbulence Factor = 10.0%

Perf. Safety Margin = 5.0%

#### Results:

Hub Average Wind Speed (m/s) = 5.96

Air Density Factor = -3%

Average Output Power (W) = 0.27

Daily Energy Output (kWh) = 6.3

Annual Energy Output (kWh) = 2,285

Monthly Energy Output = 190

Percent Operating Time = 76.1%

#### **Weibull Performance Calculations**


Wind Speed Bin (m/s)	Power (kW)	Wind Probability (f)	Net kW @ V
1	0.00	4.37%	0.00
2	0.00	8.17%	0.00
3	0.02	10.96%	0.00
4	0.05	12.49%	0.01
5	0.10	12.78%	0.01
6	0.17	11.99%	0.02
7	0.28	10.47%	0.03
8	0.44	8.56%	0.04
9	0.60	6.59%	0.04
10	0.76	4.79%	0.04
11	0.92	3.30%	0.03
12	1.10	2.15%	0.02
13	1.19	1.33%	0.02
14	1.21	0.79%	0.01
15	1.20	0.44%	0.01
16	1.17	0.24%	0.00
17	1.13	0.12%	0.00
18	1.09	0.06%	0.00
19	1.03	0.03%	0.00
20	0.96	0.01%	0.00
2000, Bergey Windpower Co	Totals:	99.62%	0.27

#### Weibull Calculations:

Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2)) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous, 24 hour, basis. Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly average speeds is not



# **Hybrid Systems Design**



- 1. Use Best Available Information and Experience from Similar Installations to Establish Load (kWh/day) Requirements
  - Load Estimates, Particularly in AC Systems, are Uncertain
  - Load Growth Often Considered at First, But Often Dropped
  - "Load Counting" Method is Common
- 2. Convert AC Energy Requirements to DC Using Balanceof-System Efficiency, Such As:
  - Battery Net Efficiency = 85%
  - Inverter Net Efficiency = 90%
  - Wiring Net Efficiency = 96%
  - "Controls" Net Efficiency = 90%



Total B.O.S. Efficiency = ~70%



- 3. Use Best Available Information to Establish Monthly Average Wind Speed Estimates
  - Usually as SWAG, So Safety Margins are Prudent
- 4. Establish Site Conditions and Other Parameters
  Necessary for the Appropriate BWC Performance Model Calculate Turbine Performance (DEO) for Each Month
- 5. Use Best Available Solar Resource Information to Establish Monthly Average Peak Sun Hours or kWh/m2/day
  - First Approximation: PSH x Array Size = Daily Energy
- 6. Calculate "Load Coverage" for each Month
  - LC < 100% means back-up required</li>
  - LC > 100% means dumped energy
  - Recommend Annual Average LC ~ 75% for hybrids with diesel back-up



#### 7. Iterate Calculations to Fit Project Design Goal

- Minimum Renewables Fraction
- Typically, Renewables Fraction is Left up to Us to Propose
- Minimum COE Usually NOT Scrutinized

## 8. Choose Complete System Architecture - Single Line Schematic

#### 9. Size Battery Bank

- Rule of Thumb: AH = 6 Times Rated Wind + PV Current
- Higher AH for Telecom, Reduced Diesel Usage, Etc.
- Lower AH for Larger Systems, Trade Winds, Etc.



#### 10. Size Inverter

- Rule of Thumb: Inverter kW = Total Renewables kW
- Watch for High Surge Requirements (Induction Motors)
- Bigger is Generally Better

#### 11. Size Back-up Generator

- Rule of Thumb: Generator kW = 1.25 x Total Renewables kW
- Watch for Big Intermittent Loads (eg, commercial ice maker)
- Too Big is Bad

#### 12. Complete Balance of Systems Design

Tend to Favor Certain BOS Component Suppliers (eg, Trace inverters) ... Design Standardization has Many Benefits

#### 13. Prepare Equipment & Services Budget



### **Load Counting**

- **Count and Define DC** Loads
- Count and Define AC Loads
- Use Reference Lists for **Typical Appliance Power** Requirements
- Set BOS Efficiency **Assumptions and Safety Margin to Calculate Equivalent Daily Energy** at the DC Bus



#### **HyCad**

Bus Type Hybrid Systems using Wind & Solar Powe

Village / Site:	Village
Country:	Mexico
Date:	11/30/00
Prepared By:	MB

#### Module 1: Loads Definition and Generation Requirements Worksheet

	Voltage (DC): This Year:	48 2000					
	Design Year:	2000					
Load No.	Description	How Many?	Power Req'd (W)	Hours Per Day	Daily Energy Now (DC kWh)	Load Growth Rate	Design Daily Energy (DC kWh
1		0			0.0	0.0%	0.0
2					0.0	0.0%	0.0
3					0.0	0.0%	0.0
4					0.0	0.0%	0.0
5					0.0	0.0%	0.0
6					0.0	0.0%	0.0
7					0.0	0.0%	0.0
8					0.0	0.0%	0.0
9					0.0	0.0%	0.0
10					0.0	0.0%	0.0
11					0.0	0.0%	0.0
12					0.0	0.0%	0.0
13					0.0	0.0%	0.0
14					0.0	0.0%	0.0
15					0.0	0.0%	0.0
15			otal (DC	kWh):	0.0 <b>0.0</b>	0.0%	0. <b>0</b> .

		Tota	al Amp-	Hours:	0		0
ternatin	g Current (AC) Lo	ads					
	Voltage (AC): Frequency: This Year: Design Year:	230 50 2000 2000			Daile	1 1	Danisa
			Power	Hours	Daily Energy	Load	Design Daily
Load		How	Rea'd	Per	Now	Growth	Energy
No.	Description	Many?	(W)	Day	(AC kWh)	Rate	(AC kWh
1	12 W CF Light	30	12	5	1.8	1.5%	1.8
2	16W CF Light	20	16	5	1.6	1.5%	1.6
3	60 W Light	10	60	5	3.0	1.5%	3.0
4	TV Set	10	120	6	7.2	1.5%	7.2
5	Radio	20	15	10	3.0	1.5%	3.0
6	Fans	20	75	8	12.0	1.5%	12.0
7	Refrigerator	4	140	24	13.4	1.5%	13.4
8	-				0.0	1.5%	0.0
9					0.0	1.5%	0.0
10					0.0	1.5%	0.0
11					0.0	1.5%	0.0
12					0.0	1.5%	0.0
13					0.0	1.5%	0.0
14					0.0	1.5%	0.0
15					0.0	1.5%	0.0
		To	tals (AC	kWh):	42.0		42.0

Balance of System (BOS) Efficiencies

PG. 1

Daily Design DC Load (kWh): 0.0	
-	
oads Summarv	

DC Energy Input Requirement					
For DC Loads (DC kWh):	0.0				
For AC Loads (DC kWh):	66.9				
Total Daily DC kWh Reg'd:	66.9				

### **Load Counting**

# AC Loads

			Power	Hours	Daily Energy	Load	Design Daily
Load		How	Req'd	Per	Now	Growth	Energy
No.	Description	Many?	(W)	Day	(AC kWh)	Rate	(AC kWh)
1	12 W CF Light	30	12	5	1.8	1.5%	1.8
2	16W CF Light	20	16	5	1.6	1.5%	1.6
3	60 W Light	10	60	5	3.0	1.5%	3.0
4	TV Set	10	120	6	7.2	1.5%	7.2
5	Radio	20	15	10	3.0	1.5%	3.0
6	Fans	20	75	8	12.0	1.5%	12.0
7	Refrigerator	4	140	24	13.4	1.5%	13.4
8					0.0	1.5%	0.0
9					0.0	1.5%	0.0
10					0.0	1.5%	0.0
11					0.0	1.5%	0.0
12					0.0	1.5%	0.0
13					0.0	1.5%	0.0
14					0.0	1.5%	0.0
15					0.0	1.5%	0.0
		To	tals (AC	kWh):	42.0		42.0

# **BOS Efficiencies**




Balance of System (BOS) Efficiencies				
Component / Aspect		DC	AC	
Net Battery:	0.85	0.85	0.85	
Inverter:	0.90	N.A.	0.90	
Regulators:	0.98	0.98	0.98	
Wiring:	0.98	0.98	0.98	
Other:	1.00	1.00	1.00	
Dumped Energy:	0.95	0.95	0.95	
Safety Margin: 0.90 0.90				
-	Total:	0.70	0.63	

### **Load Counting**

Resolving Loads to DC Energy Requirements

Daily Design DC Load (kWh):	0.0
Daily Design AC Load (kWh):	42.0

DC Energy Input Requirement			
For DC Loads (DC kWh):	0.0		
For AC Loads (DC kWh):	66.9		
Total Daily DC kWh Req'd:	66.9		



The Renewable Energy Equipment needs to Average ~70 kWh DC / day to Satisfy the 42 kWh AC / day Total Load



# **Appliance Loads**

Appliance Type	Watts/Hour	Appliance Type	Watts/Hour
Coffee pot (10 cup)	1200	VCR -Off/Play	10/27
Coffee pot (4 cup)	650	CD Player	35
Toaster	1050	Stereo	10-300
Popcorn popper	250	Clock Radio	2
Blender	300	AM/FM car tape	8+
Microwave	600-1500	Satellite dish	30+
Waffle iron	1200	CB radio	5
Hot plate	1200	Electric clock	3
Frying pan	1200	Dishwasher	1200-1500
Sink waste disposal	450	Sewing machine	100
Washing machine		Vacuum cleaner	
- automatic	920	- upright	300-1100
- manual	300+	- hand	100
Clothes dryer		Radio telephone	
- electric	4000	- receive	5
- gas heated	300-400	- transmit	40-150
Iron	1000	Furnace blower	300-1000
Garage door opener	350	Ceiling fan	10-50
Table fan	10-250	Electric blanket	200
Blow dryer	1000+	Shaver	15
Waterpik	100	Electric mower	1500



# **Appliance Loads**

Appliance Type	Watts/Hour	Appliance Type	Watts/Hour
Computer		TV	
- laptop	20-50	- 25" color	150
- pc	80-220	- 19" TV or monitor	70-140
- printer-	50/600/180	- 12" b&w	20
inkjet/laserjet/dotmatrix			
Lights		Compact fluorescent	
- 100w incandescent	100	incandescent equivalents	•
- 25w compact fluor.	28	- 40watt equiv.	11
- 50w DC incandescent	50	- 60watt equiv.	16
- 40w DC halogen	40	- 75watt equiv.	20
- 20w DC compact fluor.	22	- 100watt equiv.	30
Hedge trimmer	450	Weed eater	500
1/4" drill	250+	9" disc sander	1200
1/2" drill	450+	3" belt sander	625-1000
1" drill	800	12" chain saw	1100-2400
7 1/4" circ. saw	1200+	14" band saw	1100-1800
8 1/4" circ. saw	1800	Typewriter	80-200
Air conditioner		Refrig/freezer	
- room	1000+	- 20cf (15 hours)	540
- central	2000-5000	- 16cf (13 hours)	475
Sunfrost (figure running		Freezer (figure running	
7hrs/day typically)		10hrs/day typically)	
- 16cf DC	112	- 14cf ff (15)	440
- 12cf DC	70	- 14cf (14)	350



### **Basic Hybrid Performance Model**

#### **Projected Daily Energy Output, By Month**

Load: Daily DC kWh: 3.8 **BOS Efficiencies** Sources: DC Equivalent kWh: 8.0 Battery: Inverter: **Iterate** Wind Array Size, kW: 1.5 Wiring: 0.98 PV Array Size, kW: 0.4 Misc.: 0.9 Total: 0.706

Month	1.5 kW Wind Daily Energy Output, kWh	1 kW PV Daily Energy Output, kWh	Wind Daily Energy Output, kWh	PV Daily Energy Output, kWh	Total Daily Energy Output, kWh	Load Coverage %
JAN	2.9	5.4	2.9	2.2	5.1	94%
FEB	3.5	5.5	3.5	2.2	5.7	106%
MAR	5.0	5.4	5.0	2.2	7.2	133%
APR	7.5	4.2	7.5	1.7	9.2	170%
MAY	9.1	3.3	9.1	1.3	10.4	193%
JUN	10.6	3.1	10.6	1.2	11.8	220%
JUL	10.2	3.1	10.2	1.2	11.4	212%
AUG	9.8	3.7	9.8	1.5	11.3	209%
SEP	8.6	4.5	8.6	1.8	10.4	193%
ОСТ	7.2	5.5	7.2	2.2	9.4	175%
NOV	5.6	5.6	5.6	2.2	7.8	146%
DEC	4.1	5.4	4.1	2.2	6.3	116%
Annual Ave.	7.0	4.6	7.0	1.8	8.8	164%



### **Example Design Study**

- Remote Home Electrification
- Pine Ridge Indian Reservation, Pine Ridge, South Dakota
- ~ 130 Homes without Electricity
- Planning a 10 System Pilot Project
- Nationally, 14.2% of Indian Homes are Without Electricity, Compared to 1.4% of all American Homes



### Loads

#### Alternating Current (AC) Loads

Voltage (AC):
Frequency:
60
This Year:
1998
Design Year:
1998

		,	•		Daily		Design
•			Power	Hours	Energy	Load	Daily
Load		How	Req'd	Per	Now	Growth	Energy
No.	Description	Many?	(W)	Day	(AC kWh)	Rate	(AC kWh)
1	Refrigerator	1	90	5	0.5	1.5%	0.5
2	Microwave	1	1,000	1	1.0	1.5%	1.0
3	Lights	5	30	6	0.9	1.5%	0.9
4	Ceiling Fan	1	80	6	0.5	1.5%	0.5
5	TV	1	100	3	0.3	1.5%	0.3
6	Stereo	1	120	2	0.2	1.5%	0.2
7					0.0	1.5%	0.0
8					0.0	1.5%	0.0
9					0.0	1.5%	0.0
10					0.0	1.5%	0.0
11					0.0	1.5%	0.0
12					0.0	1.5%	0.0
13			-		0.0	1.5%	0.0
14					0.0	1.5%	0.0
15			-		0.0	1.5%	0.0
		To	otals (AC	kWh):	3.4		3.4



### Wind Resources

#### **Annual Wind Data**

Prepared For: Site Location: Bergey WindPower Company Pine Ridge Indian Reservation, SD US DOE Wind Energy Resource Atlas

Data Source: Date:


30/11/2000 Rapid City, SD

Data Collection Location: Data Collection Height (m):

19.2

Season	Average windspeed
Winter	6.6
Spring	6.9
Summer	5.7
Fall	6.6
Annual	6.45

Month	Average
	windspeed
Jan	6.60
Feb	6.70
Mar	6.80
Apr	6.90
May	6.50
Jun	6.10
Jul	5.70
Aug	6.00
Sep	6.30
Oct	6.60
Nov	6.60
Dec	6.60
avg	6.45





## Solar Resources

#### **Annual Solar Data**


Prepared For: Bergey WindPower Company
Site Location: Pine Ridge Indian Reservation, SD

Data Source: NASA Satellite Data

Date: 30/11/2000

Data Collection Location: Cell 5601, 42.50 to 45.00 N, 100.38 to 103.85 W

Month	Average
	Sun Hours
Jan	1.71
Feb	2.20
Mar	3.40
Apr	5.41
May	6.21
Jun	7.13
Jul	6.97
Aug	5.85
Sep	4.26
Oct	3.09
Nov	1.72
Dec	1.50
avg	4.12







#### **WindCad Turbine Performance Model**

#### **BWC XL.1 Battery Charging Version**

MS Excel, V.97 PC

Prepared For: Bergey WindPower Co.
Site Location: Pine Ridge, SD, USA
Data Source: US-DOE Wind Energy Atlas

Date: 11/30/00

1 kW

#### Inputs:

**Ave. Wind (m/s) =** 6.45 **Weibull K =** 2

Site Altitude (m) = 981 Wind Shear Exp. = 0.220

Anem. Height (m) = 19.2 Tower Height (m) = 10

Turbulence Factor = 5.0%

Perf. Safety Margin = 5.0%

#### Results:

Mind Drobobility (6)

99.57%

Hub Average Wind Speed (m/s) = 5.59

Air Density Factor = -9.0%

Nat W @ V

243.69

Average Output Power (W) = 244

Daily Energy Output (kWh) = 5.6

Annual Energy Output (kWh) = 2,028

Monthly Energy Output = 169

Percent Operating Time = 85.5%

Weibull Performance Calculations

2000, Bergey Windpower Co.

Wind Speed Bin (m/s)	Power (W)	Wind Probability (f)	Net W @ V
1	0	4.95%	0.00
2	2	9.17%	0.16
3	19	12.11%	2.30
4	52	13.52%	7.01
5	108	13.45%	14.54
6	199	12.21%	24.28
7	324	10.25%	33.22
8	458	8.00%	36.67
9	605	5.85%	35.40
10	761	4.01%	30.53
11	925	2.59%	23.97
12	1,037	1.58%	16.36
13	1,063	0.91%	9.64
14	1,037	0.49%	5.10
15	994	0.25%	2.51
16	947	0.12%	1.16
17	899	0.06%	0.51
18	856	0.02%	0.21
19	813	0.01%	0.08
20	769	0.00%	0.03

Totals:

#### Weibull Calculations:

average speeds is not

Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2)) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous. 24 hour, basis. Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly




# Hybrid Model

### Projected Daily Energy Output, By Month Pine Ridge Indian Reservation, SD

Load: Daily DC kWh:	3.4	BOS Efficiencies	
Sources: DC Equivalent kWh:	5.10	Battery:	0.85
		Inverter:	0.9
Wind Array Size, kW:	1	Wiring:	0.98
PV Array Size, kW:	0.2	Misc.:	0.89
		Total:	0.667

Month	1.0 kW Wind Daily Energy Output, kWh	1 kW PV Daily Energy Output, kWh	Wind Daily Energy Output, kWh	PV Daily Energy Output, kWh	Total Daily Energy Output, kWh	Avg. Daily Load	Load Coverage %
JAN	5.8	1.5	5.8	0.3	6.1	5.10	120%
FEB	6.0	1.9	6.0	0.4	6.4	5.10	126%
MAR	6.2	2.9	6.2	0.6	6.8	5.10	134%
APR	6.4	4.6	6.4	0.9	7.3	5.10	144%
MAY	5.7	5.3	5.7	1.1	6.7	5.10	132%
JUN	4.9	6.1	4.9	1.2	6.1	5.10	120%
JUL	4.1	5.9	4.1	1.2	5.3	5.10	105%
AUG	4.7	5.0	4.7	1.0	5.7	5.10	112%
SEP	5.3	3.6	5.3	0.7	6.0	5.10	118%
OCT	5.8	2.6	5.8	0.5	6.4	5.10	125%
NOV	5.8	1.5	5.8	0.3	6.1	5.10	120%
DEC	5.8	1.3	5.8	0.3	6.1	5.10	120%
Annual Ave.	5.6	4.1	5.6	0.7	6.3	5.10	123%





### **Proposed Systems**

#### 10 Systems:

- > 1 kW wind turbine, with 9 m guyed tower (\$1,985)
- 0.2 kW solar array, mounted to wind turbine tower (\$1,460)
- 10.6 kWh battery bank (\$760)
- 0.5 kW inverter, with battery-charging (\$495)
- 0.9 kW gas-powered back-up generator (\$750)
- Wiring kit (\$360)
- 9.5 ft3 high-efficiency refrigerator (\$400)
- (5) high-efficiency CF lights (\$125)

Add:

Shipping (\$360)

Installation (\$1,000)

Training (\$250)

Total: \$1,550

Total Installed Cost: \$7,885 per system



**Equipment Total: \$6,335 each**